




NORTH DUM DUM MUNICIPALITY

163, M.B.ROAD, BIRATI, KOLKATA - 700051
PHONE: (033) 2514 - 2101 / 2514 - 2494, FAX - (033) 2514 - 2990
Website: <http://www.northdumdummunicipality.org>
E-mail ID: nddmboc@bsnl.in



Memo No:NDDM/WW/4313

Date: 17.10.19

Quotation Notice

Sealed Quotation are invited from reliable, resourcefull Quotationer for :

- A) Sinking of 1(one) no Tubewell 100 mm x 50 mm and installation of submersible pump at Mahanagar Community Centre, Ward No 12

Terms and Conditions:

- i) Application in letter headed pad duly signed in. letter head should contain full address, telephone.no, mobile no., fax & e-mail along with following technical Documents-
- ii) Quotation rate Schedule
- iii) Rate to be quoted both in Words & Figures and inclusive of all taxes and charges(**GST & CESS**)
- iv) Upto date Professional tax clearance receipts
- v) IT Pan card & Tax return receipts
- vi) Upto date GST registration certificate and valid Return certificate of the last quarter of the current financial year
- viii) Credential
- ix) The Authority reserves the right to accept or reject any or all Quotation without assiging any reasons whatsoever.

Application to be made for collecting Quotation Paper.


- 1)Last Date of Receiving Quotation: 24.10.2019 upto 3 P.M.
- 2)Date of Opening Quotation: 25.10.2019 at 4 P.M.

Quation Paper Dropping: At the office of Executive Officer Chamber.


Detailed information may be available from the Water Works Department and Municipality website (<http://www.northdumdummunicipality.org>).

A) Sinking of 1(one) no Tubewell 100 mm x 50 mm and installation of submersible pump at Mahanagar Community Centre, Ward No 12


SI no	Description of work	Qty	unit	Rate(Rs)	Amount(Rs)
1	PVC pipe & fittings (medium duty) conforming to ASTM D-1785 and threaded to match with GI pipes as per IS:1239 (part-i)				
	i). 50mm dia	30.00	m		
	iii) 100 mm dia	35.00	m		
2	Supplying H. Density Polythene Strainer of approved make with adapter conforming to I.S. specification.				
	ii) 50 mm dia	7.00	m		
3	PVC pipe & fittings (medium duty) conforming to ASTM D-1785 and threaded to match with GI pipes as per IS:1239 (part-i)				
	L) Reducing Socket 100mm dia x 50mm dia:	1.00	no		
	50mm x 40mm dia	1.00	no		
	F)(iii) Nipple 150mm long 100mm dia	1.00	no		
	F)(iii) Nipple 150mm long 40mm dia	1.00	no		
4	Labour for boring Tube well of required dia by water jet system through out any type of soil strata including hire and labour charges for boring pipes, scaffolding tools and plants as necessary and taking out				




SI no	Description of work	Qty	unit	Rate(Rs)	Amount(Rs)
	them and lowering pipes strainer and pipe etc. and fitting fixing same complete including bracket washing and other incidental works in the connection. The Tubewell should have a minimum 50mm gap in between the out side of Tubewell pipe and the bore.				
	d) For depth above 150 Mtr. for 50mm dia Tubewell with top enlargement of 100mm dia.				
	i.) 50mm dia boring etc.	37.00	m		
	ii).100mm dia boring top enlargement	35.00	m		
5	Supplying, fitting and fixing steel cutter piece upto 450 mm long with sockets.				
	ii) 50mm dia	1.00	no		
6	Supplying, fitting and fixing plug of approved make conforming to I.S. Specification.				
	i). 50mm dia.	1.00	no		
7	Supply of galvanised iron socket with ISI mark				
	v) 40mm dia	2.00	no		
8	Supplying, fittings and fixing G.I.cap at top 100mm	1.00	no		
9	Washing and developing tube well with Air Compressor pump And Engine for 8(Eight)hours continuous pumping per day with necessary arrangements for testing the	1.00	day		



Sl no	Description of work	Qty	unit	Rate(Rs)	Amount(Rs)
	yield in gallons per hour with V-notch including hire and balour full charges for all tolls and plants and sacforlding per day as required.				
10	Supplying fitting and fixing submersible pump set and other accessories suitable for 80mm dia bore hole having following specification. a)Cromton graves/ Varuna etc(out let size 32mm dia). Standard voltage 200-240 Volt, Motor- Single phase, 50HZ. Ac supply, Head 48mtr, Discharge-44, L.P.M. HP-1, Stage 8 & Supply of single phase D.T. Starter control panel suitable for the supplied submersible pump set with all other accessories etc. as necessary all complete as per direction of the E.I.C	1.00	no		
11	Supply of Submersible Flat Cable suitable for above material (Make : "FINOLEX" 1.5 Sq mm ISI 3 core PVC insulated and copper insulated(High & low combind) cable	15.78	m		
12	40mm dia UPVC column pipes suitable for submersible pump with socket(3mtr length)	8.00	m		
				Rs	




 Signature Of Chairman
 North Dum Dum Municipality