



TEST REPORT

INFORMATION ON:

Sample Supplied by	: North Dum Dum Municipality	Type of Unit	: Municipality
		Sample supplied on	: 16.11.2022
Address	: 163, M. B. Road, Birati, Kolkata - 700051	Sample received on	: 17.11.2022
		Date of Issue	: 21.11.2022
Type of Sample	: Water Sample	Sample Code	: UGR ESR Campus, Ward No. - 24, K.N.I Sarani
Sample Condition	: Sealed	Report No.	: ENV/778/TR(W)/M(i)/22-23

RESULTS:

PARAMETERS	METHOD	UNIT	RESULTS
1. pH	IS 3025 (Part 11) : 2022	--	7.47
2. Conductivity	APHA 23 rd Ed., 2510 - B : 2017	µs/cm	405.6
3. Total Dissolved Solids	IS 3025 (Part 16) : 2017	mg./l	395.0
4. Turbidity	IS 3025 (Part 10) : 2017	NTU	<1.0
5. Total Hardness	IS 3025 (Part 21) : 2019	mg./l	240.0
6. Total Alkalinity	IS 3025 (Part 23) : 2019	mg./l	170.0
7. Chloride	IS 3025 (Part 32) : 2019	mg./l	44.98
8. Iron	IS 3025(Part 53) : 2019	mg./l	0.20
9. Arsenic	IS 3025 (Part 37) : 2019	mg/l	<0.01
10. Nitrate	IS 3025 (Part 34) : 2019	mg./l	1.23
11. Salinity	--	mg./l	Nil
12. Residual Free Chlorine	IS 3025 (Part 26) : 2021	mg./l	<0.1
13. Total Coliform	9222 B, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent
14. E. Coli	9222 I, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent

Remarks : a) This sample is supplied by the client and the general information is provided by the client.
b) CFU indicates Colony Forming Unit.
c) The water quality is satisfactory as per IS:10500 : 2012.

Authorised Signatory :

Dr. SUMIT CHOWDHURY
Scientist

Seen
Rajm Bhand



TEST REPORT

INFORMATION ON:

Sample Supplied by	: North Dum Dum Municipality	Type of Unit	: Municipality
		Sample supplied on	: 16.11.2022
Address	: 163, M. B. Road, Birati, Kolkata - 700051	Sample received on	: 17.11.2022
		Date of Issue	: 21.11.2022
Type of Sample	: Water Sample	Sample Code	: UGR ESR Campus, Ward No. - 24, K.N.I Sarani
Sample Condition	: Sealed	Report No.	: ENV/778/TR(W)/M(i)/22-23

RESULTS:

PARAMETERS	METHOD	UNIT	RESULTS
1. pH	IS 3025 (Part 11) : 2022	--	7.47
2. Conductivity	APHA 23 rd Ed., 2510 - B : 2017	µs/cm	405.6
3. Total Dissolved Solids	IS 3025 (Part 16) : 2017	mg./l	395.0
4. Turbidity	IS 3025 (Part 10) : 2017	NTU	<1.0
5. Total Hardness	IS 3025 (Part 21) : 2019	mg./l	240.0
6. Total Alkalinity	IS 3025 (Part 23) : 2019	mg./l	170.0
7. Chloride	IS 3025 (Part 32) : 2019	mg./l	44.98
8. Iron	IS 3025(Part 53) : 2019	mg./l	0.20
9. Arsenic	IS 3025 (Part 37) : 2019	mg/l	<0.01
10. Nitrate	IS 3025 (Part 34) : 2019	mg./l	1.23
11. Salinity	--	mg./l	Nil
12. Residual Free Chlorine	IS 3025 (Part 26) : 2021	mg./l	<0.1
13. Total Coliform	9222 B, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent
14. E. Coli	9222 I, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent

Remarks : a) This sample is supplied by the client and the general information is provided by the client.
b) CFU indicates Colony Forming Unit.
c) The water quality is satisfactory as per IS:10500 : 2012.

Authorised Signatory :

Dr. SUMIT CHOWDHURY
Scientist

Seen
Rajendra Kumar

TEST REPORT

INFORMATION ON:

Sample Supplied by	: North Dum Dum Municipality	Type of Unit	: Municipality
		Sample supplied on	: 16.11.2022
Address	: 163, M. B. Road, Birati, Kolkata - 700051	Sample received on	: 17.11.2022
		Date of Issue	: 21.11.2022
Type of Sample	: Water Sample	Sample Code	: Ambedkar Park ESR, Ward No. - 9, Bipin Paul Road
Sample Condition	: Sealed	Report No.	: ENV/778/TR(W)/M(ii)/22-23

RESULTS:

	PARAMETERS	METHOD	UNIT	RESULTS
1.	pH	IS 3025 (Part 11) : 2022	--	7.53
2.	Conductivity	APHA 23 rd Ed., 2510 - B : 2017	µs/cm	430.2
3.	Total Dissolved Solids	IS 3025 (Part 16) : 2017	mg./l	404.0
4.	Turbidity	IS 3025 (Part 10) : 2017	NTU	<1.0
5.	Total Hardness	IS 3025 (Part 21) : 2019	mg./l	240.0
6.	Total Alkalinity	IS 3025 (Part 23) : 2019	mg./l	160.0
7.	Chloride	IS 3025 (Part 32) : 2019	mg./l	49.98
8.	Iron	IS 3025(Part 53) : 2019	mg./l	0.25
9.	Arsenic	IS 3025 (Part 37) : 2019	mg/l	<0.01
10.	Nitrate	IS 3025 (Part 34) : 2019	mg./l	1.12
11.	Salinity	--	mg./l	Nil
12.	Residual Free Chlorine	IS 3025 (Part 26) : 2021	mg./l	<0.1
13.	Total Coliform	9222 B, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent
14.	E. Coli	9222 I, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent

Remarks : a) This sample is supplied by the client and the general information is provided by the client.
 b) CFU indicates Colony Forming Unit.
 c) The water quality is satisfactory as per IS:10500 : 2012.

Authorised Signatory :

Dr. SUMIT CHOWDHURY
 Scientist

Seen
 Rm/Rms

TEST REPORT

INFORMATION ON:

Sample Supplied by	: North Dum Dum Municipality	Type of Unit	: Municipality
		Sample supplied on	: 16.11.2022
Address	: 163, M. B. Road, Birati, Kolkata - 700051	Sample received on	: 17.11.2022
		Date of Issue	: 21.11.2022
Type of Sample	: Water Sample	Sample Code	: Tuki Taki ESR, Ward No. - 33, Kalaberia Road
Sample Condition	: Sealed	Report No.	: ENV/778/TR(W)/M(iii)/22-23

RESULTS:

PARAMETERS	METHOD	UNIT	RESULTS
1. pH	IS 3025 (Part 11) : 2022	--	7.49
2. Conductivity	APHA 23 rd Ed., 2510 - B : 2017	µs/cm	411.7
3. Total Dissolved Solids	IS 3025 (Part 16) : 2017	mg./l	392.0
4. Turbidity	IS 3025 (Part 10) : 2017	NTU	<1.0
5. Total Hardness	IS 3025 (Part 21) : 2019	mg./l	230.0
6. Total Alkalinity	IS 3025 (Part 23) : 2019	mg./l	160.0
7. Chloride	IS 3025 (Part 32) : 2019	mg./l	44.98
8. Iron	IS 3025(Part 53) : 2019	mg./l	0.25
9. Arsenic	IS 3025 (Part 37) : 2019	mg/l	<0.01
10. Nitrate	IS 3025 (Part 34) : 2019	mg./l	1.36
11. Salinity	--	mg./l	Nil
12. Residual Free Chlorine	IS 3025 (Part 26) : 2021	mg./l	<0.1
13. Total Coliform	9222 B, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent
14. E. Coli	9222 I, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent

Remarks : a) This sample is supplied by the client and the general information is provided by the client.
 b) CFU indicates Colony Forming Unit.
 c) The water quality is satisfactory as per IS:10500 : 2012.

Authorised Signatory :



Dr. SUMIT CHOWDHURY
Scientist



TEST REPORT

INFORMATION ON:

Sample Supplied by	: North Dum Dum Municipality	Type of Unit	: Municipality
		Sample supplied on	: 16.11.2022
Address	: 163, M. B. Road, Birati, Kolkata - 700051	Sample received on	: 17.11.2022
		Date of Issue	: 21.11.2022
Type of Sample	: Water Sample	Sample Code	: Kholishakota Pally ESR, Ward No.19, Kholishakota- Main Road, 3 No. Block
Sample Condition	: Sealed	Report No.	: ENV/778/TR(W)/M(iv)/22-23

RESULTS:

PARAMETERS	METHOD	UNIT	RESULTS
1. pH	IS 3025 (Part 11) : 2022	--	7.42
2. Conductivity	APHA 23 rd Ed., 2510 - B : 2017	µs/cm	406.2
3. Total Dissolved Solids	IS 3025 (Part 16) : 2017	mg./l	397.0
4. Turbidity	IS 3025 (Part 10) : 2017	NTU	<1.0
5. Total Hardness	IS 3025 (Part 21) : 2019	mg./l	240.0
6. Total Alkalinity	IS 3025 (Part 23) : 2019	mg./l	170.0
7. Chloride	IS 3025 (Part 32) : 2019	mg./l	49.98
8. Iron	IS 3025(Part 53) : 2019	mg./l	0.19
9. Arsenic	IS 3025 (Part 37) : 2019	mg./l	<0.01
10. Nitrate	IS 3025 (Part 34) : 2019	mg./l	1.17
11. Salinity	--	mg./l	Nil
12. Residual Free Chlorine	IS 3025 (Part 26) : 2021	mg./l	<0.1
13. Total Coliform	9222 B, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent
14. E. Coli	9222 I, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent

Remarks : a) This sample is supplied by the client and the general information is provided by the client.
 b) CFU indicates Colony Forming Unit.
 c) The water quality is satisfactory as per IS:10500 : 2012.

Scan
R. M. Paul

Authorised Signatory :

[Signature]

Dr. SUMIT CHOWDHURY
 Scientific

TEST REPORT

INFORMATION ON:

Sample Supplied by	: North Dum Dum Municipality	Type of Unit	: Municipality
		Sample supplied on	: 16.11.2022
Address	: 163, M. B. Road, Birati, Kolkata - 700051	Sample received on	: 17.11.2022
		Date of Issue	: 21.11.2022
Type of Sample	: Water Sample	Sample Code	: Opp. Of Nilam Abasan ESR, Ward No.23, Rabindra Sarani
Sample Condition	: Sealed	Report No.	: ENV/778/TR(W)/M(v)/22-23

RESULTS:

	PARAMETERS	METHOD	UNIT	RESULTS
1.	pH	IS 3025 (Part 11) : 2022	--	7.40
2.	Conductivity	APHA 23 rd Ed., 2510 - B : 2017	µs/cm	383.8
3.	Total Dissolved Solids	IS 3025 (Part 16) : 2017	mg./l	398.0
4.	Turbidity	IS 3025 (Part 10) : 2017	NTU	<1.0
5.	Total Hardness	IS 3025 (Part 21) : 2019	mg./l	240.0
6.	Total Alkalinity	IS 3025 (Part 23) : 2019	mg./l	160.0
7.	Chloride	IS 3025 (Part 32) : 2019	mg./l	44.98
8.	Iron	IS 3025(Part 53) : 2019	mg./l	0.30
9.	Arsenic	IS 3025 (Part 37) : 2019	mg/l	<0.01
10.	Nitrate	IS 3025 (Part 34) : 2019	mg./l	1.15
11.	Salinity	--	mg./l	Nil
12.	Residual Free Chlorine	IS 3025 (Part 26) : 2021	mg./l	<0.1
13.	Total Coliform	9222 B, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent
14.	E. Coli	9222 I, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent

Remarks : a) This sample is supplied by the client and the general information is provided by the client.
 b) CFU indicates Colony Forming Unit.
 c) The water quality is satisfactory as per IS:10500 : 2012.

Authorised Signatory :



Dr. SUMIT CHOWDHURY
Scientist

Seen
R.M. Bhowmik

TEST REPORT

INFORMATION ON:

Sample Supplied by	: North Dum Dum Municipality	Type of Unit	: Municipality
Address	: 163, M. B. Road, Birati, Kolkata - 700051	Sample supplied on	: 16.11.2022
		Sample received on	: 17.11.2022
Type of Sample	: Water Sample	Date of Issue	: 21.11.2022
		Sample Code	: Baktiar Uddin Ahmed, Ward No.1, Holding No. 213 (25)
Sample Condition	: Sealed	Report No.	: ENV/778/TR(W)/M(vi)/22-23

RESULTS:

PARAMETERS	METHOD	UNIT	RESULTS
1. pH	IS 3025 (Part 11) : 2022	--	7.49
2. Conductivity	APHA 23 rd Ed., 2510 - B : 2017	µs/cm	402.4
3. Total Dissolved Solids	IS 3025 (Part 16) : 2017	mg./l	402.0
4. Turbidity	IS 3025 (Part 10) : 2017	NTU	<1.0
5. Total Hardness	IS 3025 (Part 21) : 2019	mg./l	230.0
6. Total Alkalinity	IS 3025 (Part 23) : 2019	mg./l	170.0
7. Chloride	IS 3025 (Part 32) : 2019	mg./l	44.98
8. Iron	IS 3025(Part 53) : 2019	mg./l	0.21
9. Arsenic	IS 3025 (Part 37) : 2019	mg./l	<0.01
10. Nitrate	IS 3025 (Part 34) : 2019	mg./l	1.32
11. Salinity	--	mg./l	Nil
12. Residual Free Chlorine	IS 3025 (Part 26) : 2021	mg./l	<0.1
13. Total Coliform	9222 B, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent
14. E. Coli	9222 I, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent

Remarks : a) This sample is supplied by the client and the general information is provided by the client.
 b) CFU indicates Colony Forming Unit.
 c) The water quality is satisfactory as per IS:10500 : 2012.

Authorised Signatory :



Dr. SUMIT CHOWDHURY
Scientist

Seen
Rm/Rand

TEST REPORT

INFORMATION ON:

Sample Supplied by	: North Dum Dum Municipality	Type of Unit	: Municipality
Address	: 163, M. B. Road, Birati, Kolkata - 700051	Sample supplied on	: 16.11.2022
Type of Sample	: Water Sample	Sample received on	: 17.11.2022
Sample Condition	: Sealed	Date of Issue	: 21.11.2022
	Sample Code	: Sujoy Mondal & Minakshi Mondal, Ward No.3, Holding No. - 60/1	
	Report No.	ENV/778/TR(W)/M(vii)/22-23	

RESULTS:

	PARAMETERS	METHOD	UNIT	RESULTS
1.	pH	IS 3025 (Part 11) : 2022	--	7.47
2.	Conductivity	APHA 23 rd Ed., 2510 - B : 2017	µs/cm	387.4
3.	Total Dissolved Solids	IS 3025 (Part 16) : 2017	mg./l	398.0
4.	Turbidity	IS 3025 (Part 10) : 2017	NTU	<1.0
5.	Total Hardness	IS 3025 (Part 21) : 2019	mg./l	230.0
6.	Total Alkalinity	IS 3025 (Part 23) : 2019	mg./l	170.0
7.	Chloride	IS 3025 (Part 32) : 2019	mg./l	44.98
8.	Iron	IS 3025(Part 53) : 2019	mg./l	0.25
9.	Arsenic	IS 3025 (Part 37) : 2019	mg./l	<0.01
10.	Nitrate	IS 3025 (Part 34) : 2019	mg./l	1.21
11.	Salinity	--	mg./l	Nil
12.	Residual Free Chlorine	IS 3025 (Part 26) : 2021	mg./l	<0.1
13.	Total Coliform	9222 B, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent
14.	E. Coli	9222 I, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent

Remarks : a) This sample is supplied by the client and the general information is provided by the client.
 b) CFU indicates Colony Forming Unit.
 c) The water quality is satisfactory as per IS:10500 : 2012.

Authorised Signatory :


 Dr. SUMIT CHOWDHURY
 Scientist



TEST REPORT

INFORMATION ON:

Sample Supplied by	: North Dum Dum Municipality	Type of Unit	: Municipality
		Sample supplied on	: 16.11.2022
Address	: 163, M. B. Road, Birati, Kolkata - 700051	Sample received on	: 17.11.2022
		Date of Issue	: 21.11.2022
Type of Sample	: Water Sample	Sample Code	: Haran Dhar, Ward No.6, Holding No. 171 (451)
Sample Condition	: Sealed	Report No.	: ENV/778/TR(W)/M(viii)/22-23

RESULTS:

PARAMETERS	METHOD	UNIT	RESULTS
1. pH	IS 3025 (Part 11) : 2022	--	7.51
2. Conductivity	APHA 23 rd Ed., 2510 - B : 2017	µs/cm	376.4
3. Total Dissolved Solids	IS 3025 (Part 16) : 2017	mg./l	397.0
4. Turbidity	IS 3025 (Part 10) : 2017	NTU	<1.0
5. Total Hardness	IS 3025 (Part 21) : 2019	mg./l	240.0
6. Total Alkalinity	IS 3025 (Part 23) : 2019	mg./l	160.0
7. Chloride	IS 3025 (Part 32) : 2019	mg./l	49.98
8. Iron	IS 3025(Part 53) : 2019	mg./l	0.21
9. Arsenic	IS 3025 (Part 37) : 2019	mg./l	<0.01
10. Nitrate	IS 3025 (Part 34) : 2019	mg./l	1.18
11. Salinity	--	mg./l	Nil
12. Residual Free Chlorine	IS 3025 (Part 26) : 2021	mg./l	<0.1
13. Total Coliform	9222 B, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent
14. E. Coli	9222 I, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent

Remarks : a) This sample is supplied by the client and the general information is provided by the client.
 b) CFU indicates Colony Forming Unit.
 c) The water quality is satisfactory as per IS:10500 : 2012.

Authorised Signatory :



Dr. SUMIT CHOWDHURY
Scientist





TEST REPORT

INFORMATION ON:

Sample Supplied by	: North Dum Dum Municipality	Type of Unit	: Municipality
		Sample supplied on	: 16.11.2022
Address	: 163, M. B. Road, Birati, Kolkata - 700051	Sample received on	: 17.11.2022
		Date of Issue	: 21.11.2022
Type of Sample	: Water Sample	Sample Code	: Sujoy Chakraborty, Ward No.19, Holding No.236 (1239)
Sample Condition	: Sealed	Report No.	: ENV/778/TR(W)/M(ix)/22-23

RESULTS:

PARAMETERS	METHOD	UNIT	RESULTS
1. pH	IS 3025 (Part 11) : 2022	--	7.32
2. Conductivity	APHA 23 rd Ed., 2510 - B : 2017	µs/cm	313.8
3. Total Dissolved Solids	IS 3025 (Part 16) : 2017	mg./l	388.0
4. Turbidity	IS 3025 (Part 10) : 2017	NTU	<1.0
5. Total Hardness	IS 3025 (Part 21) : 2019	mg./l	230.0
6. Total Alkalinity	IS 3025 (Part 23) : 2019	mg./l	160.0
7. Chloride	IS 3025 (Part 32) : 2019	mg./l	44.98
8. Iron	IS 3025 (Part 53) : 2019	mg./l	0.21
9. Arsenic	IS 3025 (Part 37) : 2019	mg./l	<0.01
10. Nitrate	IS 3025 (Part 34) : 2019	mg./l	1.19
11. Salinity	--	mg./l	Nil
12. Residual Free Chlorine	IS 3025 (Part 26) : 2021	mg./l	<0.1
13. Total Coliform	9222 B, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent
14. E. Coli	9222 I, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent

Remarks : a) This sample is supplied by the client and the general information is provided by the client.
 b) CFU indicates Colony Forming Unit.
 c) The water quality is satisfactory as per IS:10500 : 2012.

Seen
R. M. Paul

Authorised Signatory :


 DR. SUMIT CHOWDHURY
 Scientist

TEST REPORT

INFORMATION ON:

Sample Supplied by	: North Dum Dum Municipality	Type of Unit	: Municipality
		Sample supplied on	: 16.11.2022
Address	: 163, M. B. Road, Birati, Kolkata - 700051	Sample received on	: 17.11.2022
		Date of Issue	: 21.11.2022
Type of Sample	: Water Sample	Sample Code	: Keshab Narayan Singh, Ward No.21, Holding No.229/5
Sample Condition	: Sealed	Report No.	: ENV/778/TR(W)/M(x)/22-23

RESULTS:

PARAMETERS	METHOD	UNIT	RESULTS
1. pH	IS 3025 (Part 11) : 2022	--	7.36
2. Conductivity	APHA 23 rd Ed., 2510 - B : 2017	µs/cm	403.1
3. Total Dissolved Solids	IS 3025 (Part 16) : 2017	mg./l	393.0
4. Turbidity	IS 3025 (Part 10) : 2017	NTU	<1.0
5. Total Hardness	IS 3025 (Part 21) : 2019	mg./l	250.0
6. Total Alkalinity	IS 3025 (Part 23) : 2019	mg./l	170.0
7. Chloride	IS 3025 (Part 32) : 2019	mg./l	49.98
8. Iron	IS 3025(Part 53) : 2019	mg./l	0.50
9. Arsenic	IS 3025 (Part 37) : 2019	mg./l	<0.01
10. Nitrate	IS 3025 (Part 34) : 2019	mg./l	1.24
11. Salinity	--	mg./l	Nil
12. Residual Free Chlorine	IS 3025 (Part 26) : 2021	mg./l	<0.1
13. Total Coliform	9222 B, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent
14. E. Coli	9222 I, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent

Remarks : a) This sample is supplied by the client and the general information is provided by the client.
 b) CFU indicates Colony Forming Unit.
 c) The water quality is satisfactory as per IS:10500 : 2012.

Seen
R.M. Prasad

Authorised Signatory :

Dr. Sumit Chowdhury

Dr. SUMIT CHOWDHURY
Scientist



TEST REPORT

INFORMATION ON:

Sample Supplied by	: North Dum Dum Municipality	Type of Unit	: Municipality
Address	: 163, M. B. Road, Birati, Kolkata – 700051	Sample supplied on	: 16.11.2022
Type of Sample	: Water Sample	Sample received on	: 17.11.2022
Sample Condition	: Sealed	Date of Issue	: 21.11.2022
Sample Code	: Kalpana Mullick, Ward No.31, Holding No.391	Report No.	: ENV/778/TR(W)/M(xi)/22-23

RESULTS:

PARAMETERS	METHOD	UNIT	RESULTS
1. pH	IS 3025 (Part 11) : 2022	--	7.43
2. Conductivity	APHA 23 rd Ed., 2510 – B : 2017	µs/cm	337.6
3. Total Dissolved Solids	IS 3025 (Part 16) : 2017	mg./l	402.0
4. Turbidity	IS 3025 (Part 10) : 2017	NTU	<1.0
5. Total Hardness	IS 3025 (Part 21) : 2019	mg./l	240.0
6. Total Alkalinity	IS 3025 (Part 23) : 2019	mg./l	160.0
7. Chloride	IS 3025 (Part 32) : 2019	mg./l	49.98
8. Iron	IS 3025 (Part 53) : 2019	mg./l	0.26
9. Arsenic	IS 3025 (Part 37) : 2019	mg/l	<0.01
10. Nitrate	IS 3025 (Part 34) : 2019	mg./l	1.18
11. Salinity	--	mg./l	Nil
12. Residual Free Chlorine	IS 3025 (Part 26) : 2021	mg./l	<0.1
13. Total Coliform	9222 B, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent
14. E. Coli	9222 I, APHA 23 rd Ed., 2017	CFU/100 ml.	Absent

Remarks : a) This sample is supplied by the client and the general information is provided by the client.
 b) CFU indicates Colony Forming Unit.
 c) The water quality is satisfactory as per IS:10500 : 2012.

Seem
R.M. Bandyopadhyay

Authorised Signatory :

Dr. SUMIT CHOWDHURY
 Scientist